



Notes:

1. Trench and duct installation must be inspected by Milton Hydro prior to backfilling. Backfilling prior to inspection shall result in the retrenching of the installation at the owner's expense. Trench inspection must be booked 2 working days in advance.
2. Fill shall be clean raked backfill, free of large lumps, stones etc. If clean fill is not available at site, trench must be backfilled with cable sand.
3. Install a 3/16" mm polyethylene pulling rope in the duct.
4. Supply a sufficient length of rigid PVC conduit 23' (7.0m), complete with a cable duct reducer, straps, and entrance cap for installation by Milton Hydro at the hydro supply pole.

| | | |
|---|---------------------|---------------------------------------|
| APPROVED: | milton hydro | REVISION No: 13-02 August 20/13 |
| Residential - Rural (o/h to u/g) (#3/0, 250 & 500 kcmil u/g triplex) | | DRAWING No: RU - 13C |